

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CN0103**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	August Brötje GmbH August-Brötje-Straße 17, D-26180 Rastede
Distributor <i>Vertreiber</i>	August Brötje GmbH August-Brötje-Straße 17, D-26180 Rastede
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing boiler
Model <i>Modell</i>	WHB...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CN, CY, CZ, DE, DK, EE, ES, FR, GR, HU, IT, LT, LV, NO, PL, PT, RO, SE, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: K 789 2019 B18 from 22.05.2019 (TRG) supplement test: K 789 2019 E17 from 22.05.2019 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

70028-04-A-CE

Date of Expiry / File No. 02.02.2028 / 19-0225-GEA
Ablaufdatum / AZ

24.06.2019 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	LV	
I3P	30 mbar	BE	
I3P	37 mbar	BE	
II2ELL3B/P	20, 50 mbar	DE	
II2ELw3B/P	20, 30 mbar	PL	only for WHBC 28/33 D, WHBS 30 D and WHBK 28
II2Er3+	20/25, 28-30/37 mbar	FR	
II2Esi3P	20/25, 37 mbar	FR	
II2H3+	20, 28-30/37 mbar	ES, IT	
II2H3B/P	20, 30 mbar	CH, CY, DK, EE, GR, IT, LT, NO, RO, SE, SK	
II2H3B/P	20, 37 mbar	CH, TR	
II2H3B/P	20, 50 mbar	AT, CH, CZ	
II2H3P	20, 37 mbar	ES	
II2HS3B/P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
WHBS 14 D	nominal heat output: 3,4...13,6 kW heat input (Hi): 3,5...14,0 kW	
WHBS 22 D	nominal heat output: 4,7...21,3 kW heat input (Hi): 4,9...22,0 kW	
WHBC 22/24 D; WHBK 22/24	nominal heat output: 5,2...21,3 kW heat input (Hi): 4,9...22,0 (drinking water: ...24,0) kW	
WHBC 28/33 D	nominal heat output: 6,6...27,2 kW heat input (Hi): 6,9...28,0 (drinking water: ...33,0) kW	
WHBK 28	nominal heat output: 6,6...27,2 kW heat input (Hi): 6,9...28,0 kW	
WHBS 30 D	nominal heat output: 6,6...29,1 kW heat input (Hi): 6,9...30,0 kW	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
WHBS	Condensing boiler without drinking water heating
WHBC	Condensing combi water heater
WHBK	Condensing boiler with integrated 45 l drinking water storage

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Additional proved countries of destination, appliance categories and supply pressures:

BG, PT, UA: II2H3B/P (20, 37 mbar)

UA: II2H3B/P (20, 50 mbar)

CN: II2H3P (10-20, 28 mbar)

PL (only for WHBS 14 D, WHBS 22 D, WHBC 22/24 D and WHBK 22/24): II2ELwLsLn3B/P (20, 20, 13, 13, 30 mbar)

Flue types B23, B23P, B33, B53P, C13x, C33x, C43x, C53, C53x, C63x, C83 und C93x: according to BRÖTJE installation manual 7728688

In China and in the Ukraine the conformaty approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by China respectively Ukraine.